

02-5-4310

NETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

No 15283

OPERATIONS PERMIT

Name: (owner) HILL CUSTOM HOMES New Installation Septic Tank
 Property Location: SR# US 401W Repairs Nitrification Line
 Subdivision WOODVIEW Lot # 10
 TAX ID# _____ Quadrant # _____
 Contractor: JOHNNY JONES Registration # _____

Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: 100 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____
 Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface Drainage Field No. of ditches 4 exact length of each ditch 70 ft. width of ditches 3 ft. depth of ditches 18-30 in.
 French Drain: _____ Linear feet

Date: 7/16/02

PERMIT NO. 19110

Inspected by: [Signature]
Environmental Health Specialist

