

SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940										
SLOPE (%)	.1940										
HORIZON 1 DEPTH		0-24"	0-24"	0-10"							
TEXTURE GROUP	.1941(A)(1)	SL	SL	SL							
CONSISTENCE	.1941	VFR	VFR	VFR							
STRUCTURE	.1941(A)(2)	G	G	G							
MINERALOGY	.1941(A)(3)	NS/NP	NS/NP	NS/NP							
HORIZON 2 DEPTH		24"	24"	10-36"							
TEXTURE GROUP	.1941(A)(1)	SC2	SC2	SC2							
CONSISTENCE	.1941	FR	FR	FR							
STRUCTURE	.1941(A)(2)	SBK	SBK	SBK							
MINERALOGY	.1941(A)(3)	SS/SP	SS/SP	SS/SP							
HORIZON 3 DEPTH											
TEXTURE GROUP	.1941(A)(1)										
CONSISTENCE	.1941										
STRUCTURE	.1941(A)(2)										
MINERALOGY	.1941(A)(3)										
HORIZON 4 DEPTH											
TEXTURE GROUP	.1941(A)(1)										
CONSISTENCE	.1941										
STRUCTURE	.1941(A)(2)										
MINERALOGY	.1941(A)(3)										
SOIL WETNESS	.1942			36"							
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/.1956										
CLASSIFICATION	.1948	P5	P5	P5							
LONG TERM ACCEPTANCE RANGE	.1955	.4	.4	.4							

300'
 4 x 75'
 18" - 30"
 MEET ON SITE

