

# SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

FACTORS		PROFILES													
		1	2	3	4	5	6	7	8	9	10				
LANDSCAPE POSITION	.1940														
SLOPE (%)	.1940														
HORIZON 1 DEPTH		0-30"	0-28"												
TEXTURE GROUP	.1941(A)(1)	SL	SL												
CONSISTENCE	.1941	VFR	VFR												
STRUCTURE	.1941(A)(2)	C	C												
MINERALOGY	.1941(A)(3)	NS/NLP	NS/NLP												
HORIZON 2 DEPTH		31"	29"												
TEXTURE GROUP	.1941(A)(1)	SCL	SCL												
CONSISTENCE	.1941	FR	FR												
STRUCTURE	.1941(A)(2)	SBX	SBX												
MINERALOGY	.1941(A)(3)	SS/SL	SS/SL												
HORIZON 3 DEPTH															
TEXTURE GROUP	.1941(A)(1)														
CONSISTENCE	.1941														
STRUCTURE	.1941(A)(2)														
MINERALOGY	.1941(A)(3)														
HORIZON 4 DEPTH															
TEXTURE GROUP	.1941(A)(1)														
CONSISTENCE	.1941														
STRUCTURE	.1941(A)(2)														
MINERALOGY	.1941(A)(3)														
SOIL WETNESS	.1942														
RESTRICTIVE HORIZON	.1944														
SAPROLITE	.1943/.1956														
CLASSIFICATION	.1948	PS	PS												
LONG TERM ACCEPTANCE RANGE	.1955	-4	4												

4x75'  
 PUMP TO CONV.  
 PUMP CONV. REP.

