

SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940	L	L	L							
SLOPE (%)	.1940	2	2	2							
HORIZON 1 DEPTH		0-20	0-20	0-18							
TEXTURE GROUP	.1941(A)(1)	SL	SL	SL							
CONSISTENCE	.1941	FR	FR	FR							
STRUCTURE	.1941(A)(2)	GR	GR	GR							
MINERALOGY	.1941(A)(3)	NSNP	NSNP	NSNP							
HORIZON 2 DEPTH		20-30	20-30	18-28							
TEXTURE GROUP	.1941(A)(1)	SCL	SCL	SCL							
CONSISTENCE	.1941	FR	FR	FR							
STRUCTURE	.1941(A)(2)	GR	GR	GR							
MINERALOGY	.1941(A)(3)	NSNP	NSNP	NSNP							
HORIZON 3 DEPTH		30-42	30-42	24-42							
TEXTURE GROUP	.1941(A)(1)	SC	SC	SC							
CONSISTENCE	.1941	SL FR	SL FR	SL FR							
STRUCTURE	.1941(A)(2)	SBR	SBR	SBR							
MINERALOGY	.1941(A)(3)	SSSP	SSSP	SSSP							
HORIZON 4 DEPTH											
TEXTURE GROUP	.1941(A)(1)										
CONSISTENCE	.1941										
STRUCTURE	.1941(A)(2)										
MINERALOGY	.1941(A)(3)										
SOIL WETNESS	.1942	32	32	32							
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/.1956										
CLASSIFICATION	.1948										
LONG TERM ACCEPTANCE RANGE	.1955	.4	.4	.4							