


SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940	L	C	2							
SLOPE (%)	.1940	1	2	1							
HORIZON 1 DEPTH		0-18									
TEXTURE GROUP	.1941(A)(1)	SL									
CONSISTENCE	.1941	FC									
STRUCTURE	.1941(A)(2)	CM									
MINERALOGY	.1941(A)(3)	SSNP									
HORIZON 2 DEPTH		18-24									
TEXTURE GROUP	.1941(A)(1)	SCL									
CONSISTENCE	.1941	FC									
STRUCTURE	.1941(A)(2)	CM									
MINERALOGY	.1941(A)(3)	SSNP									
HORIZON 3 DEPTH		24-36									
TEXTURE GROUP	.1941(A)(1)	SC-C									
CONSISTENCE	.1941	SI OR M									
STRUCTURE	.1941(A)(2)	SPM									
MINERALOGY	.1941(A)(3)	SSSP									
HORIZON 4 DEPTH											
TEXTURE GROUP	.1941(A)(1)										
CONSISTENCE	.1941										
STRUCTURE	.1941(A)(2)										
MINERALOGY	.1941(A)(3)										
SOIL WETNESS	.1942	32	32	32							
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/1956										
CLASSIFICATION	.1948										
LONG TERM ACCEPTANCE RANGE	.1955	.4	.35	.4							

BOBBY BYRD
 DB 687, PG 305
 PLAT BK. 23, PG 305



1:100

US 421 R/W WIDTH VARIES

Required Property Line Setbacks

NEW IRON STAKES (USE FOUND)	Minimum	Actual
	35'	35'
	10'	34'
	25'	132'
	10'	

NCSR # 2013

PLAN APPROVAL
 DISTRICT RA30 USE SED
 BUILDINGS 3
5-a-02 D. Johnson
 Zoning Administrator

RADIUS	L
C-1 = 50.00'	7
C-2 = 441.60'	4
C-3 = 441.60'	11
C-4 = 25.00'	3
C-5 = 25.00'	2
C-6 = 50.00'	5
C-7 = 50.00'	6
C-8 = 50.00'	6
C-9 = 50.00'	5
C-10 = 25.00'	2
C-11 = 25.00'	4
C-12 = 491.60'	27
C-13 = 25.00'	34