HTE#			
------	--	--	--

Harnett County Department of Public Health

28848

Improvement Permit

A building permit cannot be issued with only an Improvement Permit ISSUED TO: HANNAK + REON HANNOK - SUBDIVISION -PROPERTY LOCATION SX 1443 (rotagette (1) Site Improvements required prior to Construction Authorization Issuance: Type of Structure: Proposed Wastewater System Type: 2520 Recl Projected Daily Flow: 360 GPD Number of bedrooms: 3 Number of Occupants: 6 max Basement Tes Pump Required: ☐Yes ☐ No ☐ May be required based on final location and elevations of facilities Type of Water Supply:

Community Public Well Distance from well feet Five years Permit valid for: Permit conditions: ☐ No expiration The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance ISSUED TO: HANNAh + Rion Hyst PROPERTY LOCATION: SN 1443 (afayette R)


SUBDIVISION ______ LOT # 85-Basement? Yes No Basement Fixtures? Yes No Type of Wastewater System** (Initial) Wastewater Flow: 360 (See note below, if applicable Installation Requirements/Conditions Septic Tank Size 154 gallons Pump Tank Size _____ gallons Maximum Trench Depth of: ____18 _____ inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: _____ft. TDH vs. ____GPM Aggregate Depth: ______ inches below pipe inches above pipe ______ inches total Conditions: WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent Date: 5-3-16 Construction Authorization Expiration Date: 5-3-21

HTE#

Permit # _____ 28848

Harnett County Department of Public Health Site Sketch

11 1 1 0	PROPERTY LOCATON: 521443	Infragette no		
ISSUED TO: HANNAL + PEON HYATT	SUBDIVISION V. (4.	1	LOT #	85
Authorized State Agents 2 1	Imhont.	Date: 8-3-16		



Joh Alexander DL