

03-5-5276

RNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

No 15395

OPERATIONS PERMIT

Name: (owner) Gary Hughes New Installation Septic Tank
 Property Location: SR# 1443 Lafayette Rd Repairs Nitrification Line
 Subdivision Vic Halls Rd Lot # 87
 TAX ID# _____ Quadrant # _____
 Contractor: Roy Moore Registration # _____

Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: 50' ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____
 Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface Drainage Field: No. of ditches 1 exact length of each ditch 400 ft. width of ditches 3 ft. depth of ditches 18-20 in.
 French Drain: _____ Linear feet

Date: 9-30-02

PERMIT NO. 13946

Inspected by James E. Manhart
Environmental Health Specialist

