

HARNETT COUNTY HEALTH DEPARTMENT

No 15512

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) JASON PRICE

New Installation

Septic Tank

Property Location: SR# 2006 Crawford

Repairs

Nitrification Line

Subdivision _____ Lot # _____

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 1 ACRE

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other FFF-ZZZ WAY INNS 85-3R

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 18-20 in.

French Drain Required: - Linear feet

This permit is subject to revocation if site plans or intended use change.


Date: 8-27-02

Signed: James E. Manshart
Environmental Health Specialist

STUB PLUMBING OUT SHALLOW - IF NOT

50' I+E EASEMENT!

Pump will BE REQUIRED!



Changed to FFF-ZZZ WAY BY OWNER