

HTE# _____

Harnett County Department of Public Health

25747

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Wells Fargo/Karen Joseph PROPERTY LOCATION: Hay 55
 NEW REPAIR EXPANSION SUBDIVISION: Waldwinds LOT # 4
 Type of Structure: Ex SFD Site Improvements required prior to Construction Authorization Issuance: _____
 Proposed Wastewater System Type: Conventional
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years
 Permit conditions: _____ No expiration

Authorized State Agent: Jane E. Markham Date: 4-30-10 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Wells Fargo/Karen Joseph PROPERTY LOCATION: Hay 55
 Facility Type: Ex SFD New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** _____ (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable) Conventional
 Installation Requirements/Conditions
 Septic Tank Size 1000 gallons Number of trenches 1 (Repair) Added to GND of existing driveway.
 Pump Tank Size _____ gallons Exact length of each trench 50 feet Trench Spacing: 9 Feet on Center
 Trenches shall be installed on contour at a Maximum Trench Depth of: 24" inches Soil Cover: 6 inches
 (Trench bottoms shall be level to +/-1/4" in all directions) (Maximum soil cover shall not exceed 36" above the trench bottom)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: 6 inches below pipe
 Conditions: _____ 2 inches above pipe
12 inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: Jane E. Markham Date: 4-30-10
 Construction Authorization Expiration Date: 4-30


HTE# _____

Permit # 25747

Harnett County Department of Public Health Site Sketch

ISSUED TO: Wells Fargo / Karon Joseph PROPERTY LOCATION: Hwy 55
SUBDIVISION WILD WINDS LOT # 4

Authorized State Agent: James E. Markant TELE 1845 Date: 4-30-10



- * RECONNECT 2ND LINE TO END OF 3RD LINE TO GET EXTRA 50' OF DRAIN LINE;
- * ADD 50' OF LINE Below Reconnection of 2ND to 3RD LINE
- * NEW D-BOX WILL BE NEEDED.
- * CUT AND DAM UP AFTER 50' MARK.
- * STAY 15' OFF POOL AND CUT AROUND POOL.