

03-5-5666

HARNETT COUNTY HEALTH DEPARTMENT

No 19667

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) BALLARD WOODS L.L.C.
Property Location: SR# 1437 BALLARD RO
New Installation, Septic Tank, Repairs, Nitrification Line

Subdivision BALLARD WOODS Lot # 2

Tax ID # Quadrant #

Number of Bedrooms Proposed: 3 Lot Size:

Basement with Plumbing: Garage:

Water Supply: Well, Public, Community

Distance From Well: 100 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional, Other

Size of tank: Septic Tank: 1000 gallons Pump Tank:

Subsurface Drainage Field No. of ditches, exact length of each ditch, width of ditches, depth of ditches

French Drain Required: Linear feet

Date: 10/16/02


Signed: Environmental Health Specialist

This permit is subject to revocation if site plans or intended use change.

* MAINTAIN ALL SETBACKS

* CALL WITH ANY QUESTIONS PRIOR TO INSTALLATION

DRAWING NTS



23-04
18/04
18/04
11/04

105

292'

100'

HARNETT COUNTY HEALTH DEPARTMENT
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department, Improvement Permit # 19667. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

BALLARO WOODS LLC 919-215-9861
Name Telephone #

PO BOX 6127 RALEIGH NC 27628
Address

1437 BALLARO RO
Property Location SR# Road Name

BALLARO WOODS 2 3
Subdivision Lot # # Bedrooms Proposed Lot size

TYPE OF SYSTEM

New Installation [] Repair Septic Tank Nitrification Lines

Conventional Other _____

[] Basement [] With Plumbing [] Without Plumbing

Water Supply: [] Well Public - Minimum Well Setback: 100 Ft.
Septic Tank 1000 gal Pump Chamber _____


NITRIFICATION FIELD SPECIFICATIONS

Number of fields 1 # of lines per field 1 Length of lines 300 Ft.

Width of ditches 3 ft. Depth of ditches 18 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.


Signature of Authorized Agent for Harnett County

10/16/02
Date