

00-011356 (Temp#)
(REV)
(03-5-5796) New#
(00-4-0348) old#

NETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

No 15486

OPERATIONS PERMIT

Name: (owner) Keith Bullock New Installation Septic Tank
Property Location: SR# 1439 Repairs Nitrification Line
Subdivision Johnson Farms I Lot # 5
TAX ID# _____ Quadrant # _____
Contractor: Mike Ray Registration # _____

Basement with Plumbing: Garage:
Water Supply: Well Public Community
Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 2 exact length of each ditch 120 ft. width of ditches 3 ft. depth of ditches 18-24 in.

French Drain: _____ Linear feet

Date: 2/3/2005

PERMIT NO. 17757

Inspected by: Dwight M. Lewis R. S.
Environmental Health Specialist

