HAR IT COUNTY HEALTH DEPART T
ENVIRONMENTAL HEALTH SECTION

HTE 03-5-580912

16933

OPERATIONS PERMIT

Name: (owner) Comfort Homes INC

☑ New Installation ☑ Septic Tank

Property Location: SR# 1412 Christian Light RD

☐ Repairs ☑ Nitrification Line

Subdivision Forest Trails

Lot # 11

Tax ID #

Quadrant #

Contractor: Chris Thompson

Registration #

Basement with Plumbing: ☐ Garage: ☐

3 bedroom

Water Supply: ☐ Well ☑ Public ☐ Community

Distance From Well: 58' ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: ☐ Conventional ☑ Other Pump to Conventional

Size of tank: Septic Tank: 1000 gallons Pump Tank: 1000 gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 80 ft. width of ditches 3 ft. depth of ditches 18 in.

French Drain Required: — Linear feet

Date: 7-8-04

Inspected by: James E Montgomery
Environmental Health Specialist

PERMIT NO. 20724