

INDIAN NETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH SECTION

No 15766

# OPERATIONS PERMIT

Name: (owner) Gary Hughes  New Installation  Septic Tank  
 Property Location: SR# 1443 Lafayette  Repairs  Nitrification Line  
 Subdivision Victoria Wells Lot # 90  
 TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_

Contractor: MOORE EXCAVATING Registration # \_\_\_\_\_

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 50' ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional  Other \_\_\_\_\_

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface No. of exact length width of depth of  
 Drainage Field ditches 5 of each ditch 72 ft. ditches 3 ft. ditches 18-20 in.

French Drain: - Linear feet

Date: 1-17-03

PERMIT NO. 15547

Inspected by: James E. Manhart  
 Environmental Health Specialist

