

# SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

FACTORS		PROFILES													
		1	2	3	4	5	6	7	8	9	10				
LANDSCAPE POSITION	.1940														
SLOPE (%)	.1940														
HORIZON 1 DEPTH		0-10	0-8	0-16											
TEXTURE GROUP	.1941(A)(1)	LS	SL	SL											
CONSISTENCE	.1941	Vfr	Vfr	Vfr											
STRUCTURE	.1941(A)(2)	G	G	G											
MINERALOGY	.1941(A)(3)	NEH	WEH	NEH											
HORIZON 2 DEPTH		6-12	8-20	10-30											
TEXTURE GROUP	.1941(A)(1)	SL	SC	SC											
CONSISTENCE	.1941	Vfr	fr	fr											
STRUCTURE	.1941(A)(2)	G	SPK	SPK											
MINERALOGY	.1941(A)(3)	WEH	SCM	SCM											
HORIZON 3 DEPTH		12-30													
TEXTURE GROUP	.1941(A)(1)	SC													
CONSISTENCE	.1941	fr													
STRUCTURE	.1941(A)(2)	SPK													
MINERALOGY	.1941(A)(3)	SPK													
HORIZON 4 DEPTH															
TEXTURE GROUP	.1941(A)(1)														
CONSISTENCE	.1941														
STRUCTURE	.1941(A)(2)														
MINERALOGY	.1941(A)(3)														
SOIL WETNESS	.1942														
RESTRICTIVE HORIZON	.1944														
SAPROLITE	.1943/1956														
CLASSIFICATION	.1948	P5	P5	P5											
LONG TERM ACCEPTANCE RANGE	.1955	.45	.4	.45											

