

SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940	L	L	L							
SLOPE (%)	.1940	3	5	3							
HORIZON 1 DEPTH		0-18	0-18	0-18							
TEXTURE GROUP	.1941(A)(1)	SL									
CONSISTENCE	.1941	FL									
STRUCTURE	.1941(A)(2)	GL									
MINERALOGY	.1941(A)(3)	NSNP									
HORIZON 2 DEPTH		18-24	18-24	18-24							
TEXTURE GROUP	.1941(A)(1)	2CL									
CONSISTENCE	.1941	FN									
STRUCTURE	.1941(A)(2)	GL-SM									
MINERALOGY	.1941(A)(3)	SSSP									
HORIZON 3 DEPTH		24-40	24-40	24-40							
TEXTURE GROUP	.1941(A)(1)	SL-CL									
CONSISTENCE	.1941	SL Fm									
STRUCTURE	.1941(A)(2)	SBC									
MINERALOGY	.1941(A)(3)	SSSP									
HORIZON 4 DEPTH											
TEXTURE GROUP	.1941(A)(1)										
CONSISTENCE	.1941										
STRUCTURE	.1941(A)(2)										
MINERALOGY	.1941(A)(3)										
SOIL WETNESS	.1942	36	36	56							
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/1956										
CLASSIFICATION	.1948										
LONG TERM ACCEPTANCE RANGE	.1955	.4	.4	.4							