

SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940										
SLOPE (%)	.1940										
HORIZON 1 DEPTH		0-21		0-18"	0-18"						
Texture Group	.1941(A)(1)	SL		S1	SL						
Consistence	.1941	VFR		VFR	VFR						
Structure	.1941(A)(2)	G		G	G						
Mineralogy	.1941(A)(3)	NS/NP		NS/NP	NS/NP						
HORIZON 2 DEPTH		21-39		17-34"	18-32"						
Texture Group	.1941(A)(1)	SCL		SCL	SCL						
Consistence	.1941	FR		FR	FR						
Structure	.1941(A)(2)	SBK		SBK	SBK						
Mineralogy	.1941(A)(3)	SS/S		SS/S	SS/S						
HORIZON 3 DEPTH		39-43"		31-46"	32-44"						
Texture Group	.1941(A)(1)	C		C	C						
Consistence	.1941	FR		FR	FR						
Structure	.1941(A)(2)	SBK		SBK	SBK						
Mineralogy	.1941(A)(3)	S/S		S/S	S/S						
HORIZON 4 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
SOIL WETNESS	.1942										
RESTRICTIVE HORIZON	.1944			36"							
SAPROLITE	.1943/.1956										
CLASSIFICATION	.1948	PS		PS	PS						
LONG TERM ACCEPTANCE RATE	.1955	.4		.4	.4						

PH #2 - STANDING WATER @ 35"

LAST DEPTH TO BOTTOM OF PIT

H_v 75' @ 24" MAX