

SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES												
		1	2	3	4	5	6	7	8	9	10			
LANDSCAPE POSITION	.1940													
SLOPE (%)	.1940													
HORIZON 1 DEPTH		0-30	0-12	0-20	0-10"									
Texture Group	.1941(A)(1)	SC	GCL	GCL	GCL									
Consistence	.1941	FR	FR	FR	FR									
Structure	.1941(A)(2)	GR/SBK	SBK	SBK	SBK									
Mineralogy	.1941(A)(3)	NS/NP	SS/SP	SS/SP	SS/SP									
HORIZON 2 DEPTH		30-42	12-32	10-40	10-24"									
Texture Group	.1941(A)(1)	C	C	C	C									
Consistence	.1941	FR	FR	FR	FR									
Structure	.1941(A)(2)	SBK	SBK	SBK	SBK									
Mineralogy	.1941(A)(3)	SS/SP	SS/SP	SS/SP	SS/SP									
HORIZON 3 DEPTH														
Texture Group	.1941(A)(1)													
Consistence	.1941													
Structure	.1941(A)(2)													
Mineralogy	.1941(A)(3)													
HORIZON 4 DEPTH														
Texture Group	.1941(A)(1)													
Consistence	.1941													
Structure	.1941(A)(2)													
Mineralogy	.1941(A)(3)													
SOIL WETNESS	.1942	3A	2B		36'									
RESTRICTIVE HORIZON	.1944													
SAPROLITE	.1943/1956													
CLASSIFICATION	.1948	PS	PS	PS	PS									
LONG TERM ACCEPTANCE RATE	.1955	.5	.4	.4	.4									

