

SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940										
SLOPE (%)	.1940										
HORIZON 1 DEPTH		0-18"	0-20"								
Texture Group	.1941(A)(1)	SL	SL								
Consistence	.1941	VFR	VFR								
Structure	.1941(A)(2)	G	G								
Mineralogy	.1941(A)(3)	NS/NP	NS/NP								
HORIZON 2 DEPTH		18"-36"	20"-38"								
Texture Group	.1941(A)(1)	SL	SL								
Consistence	.1941	VFR	VFR								
Structure	.1941(A)(2)	SBK	SBK								
Mineralogy	.1941(A)(3)	SS/SP	SS/SP								
HORIZON 3 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
HORIZON 4 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
SOIL WETNESS	.1942		3C ¹								
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/.1956										
CLASSIFICATION	.1948	PS	PS								
LONG TERM ACCEPTANCE RATE	.1955	.5	.5								

3x80 @ 24"

