

#03-5-7564

HARNETT COUNTY HEALTH DEPARTMENT

No 19325

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) DANNY NORRIS

- New Installation
- Septic Tank
- Repairs
- Nitrification Line

Property Location: SR# 1435 Trepp Rd

Subdivision VINEYARD GREEN Lot # 21

Tax ID # \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 3 Lot Size: .461

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other EFF-222 LUMP SUMS 95-96 INNOVATIVE SYSTEM

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons


Subsurface Drainage Field No. of ditches 3 exact length of each ditch 80' width of ditches 3 ft. depth of ditches 24-18 in.

French Drain Required: \_\_\_\_\_ Linear feet

Date: 8-7-03

This permit is subject to revocation if site plans or intended use change.

Signed: James E. Mandant Environmental Health Specialist



#03-5-7564

HARNETT COUNTY HEALTH DEPARTMENT  
AUTORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department, Improvement Permit # 19325. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

DANNY NORRIS 910-892-4345  
 Name Telephone #  
P.O. BOX 727 DUNN N.C. 28335  
 Address  
1435 TRIPP  
 Property Location SR# Road Name  
VINEYARD GREEN 21 3 .461  
 Subdivision Lot # # Bedrooms Proposed Lot size

TYPE OF SYSTEM

New Installation  Repair  Septic Tank  Nitrification Lines  
 Conventional Other INNOVATIVE  Basement  With Plumbing  Without Plumbing  
 Water Supply:  Well  Public - Minimum Well Setback: \_\_\_\_\_ Ft.  
 Septic Tank 1600 Pump Chamber \_\_\_\_\_

NITRIFICATION FIELD SPECIFICATIONS

Number of fields 2 # of lines per field 3 Length of lines 50 Ft.  
 Width of ditches 3 ft. Depth of ditches 24-18 inches  
 French Drain: Linear feet required \_\_\_\_\_ Depth of gravel \_\_\_\_\_

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

James E. Mankin 8-7-03  
 Signature of Authorized Agent for Harnett County Date