

IMPROVEMENT PERMIT

03-5-7633

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Dennis Norris Builders
Property Location: SR# 1115
New Installation [checked]
Septic Tank [checked]
Repairs [unchecked]
Nitrification Line [checked]

Subdivision Peach Tree Lot # 106

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 (41x44) Lot Size: .482 ac

Basement with Plumbing: [unchecked] Garage: [checked]
Water Supply: [unchecked] Well [checked] Public [checked] Community [unchecked]
Distance From Well: 50 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: [checked] Conventional [unchecked] Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons


Subsurface Drainage Field No. of ditches: 2 exact length of each ditch: 120 ft. width of ditches: 3 ft. depth of ditches: 18 to 24 in.

French Drain Required: _____ Linear feet

Date: 8-18-03

This permit is subject to revocation if site plans or intended use change.

Signed: Joe W. [Signature] Environmental Health Specialist



STUB out Plumbing out shallow AS possible
MAINTAIN ALL setBACKS
DO NOT DRIVE OR PARK on septic system

HARNETT COUNTY HEALTH DEPARTMENT
AUTORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department, Improvement Permit # 20194. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Name Dennis, Norman Builder Telephone# 897-6080

Address _____

Property Location SR# _____ Road Name _____
1115
Plack Tree 106 3(41x44) 0482 AC
Subdivision Lot # # Bedrooms Proposed Lot Size

TYPE OF SYSTEM

New Installation Repair Septic Tank Nitrification Lines

Conventional Other _____

Basement With Plumbing Without Plumbing

Water Supply: Well Public Water Supply Minimum Well Setback: 50 Ft.

Septic Tank 1000 gal Pump Chamber _____ gal

NITIRIFICATION FIELD SPECIFICATIONS

Number of fields 1 # of lines per field 2 Length of lines 120 Ft.

Width of ditches 3 ft. Depth of ditches 18.24 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

Signature of Authorized Agent for Harnett County of Harnett [Signature] Date 8-18-00