

HTE 03-5-7681

# OPERATIONS PERMIT

Name: (owner) SK Home LLC  New Installation  Septic Tank  
 Property Location: SR# 1443  Repairs  Nitrification Line  
 Subdivision Victorian Hills PLS Lot # 183  
 Tax ID # \_\_\_\_\_ Quadrant # \_\_\_\_\_  
 Contractor: Ted Brown Registration # \_\_\_\_\_

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 50 ft.

**Following are the specifications for the sewage disposal system on above captioned property.**

Type of system:  Conventional  Other Infiltrator

Size of tank: Septic Tank: 1200 gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface Drainage Field No. of ditches 5 exact length of each ditch 80 ft. width of ditches 3 ft. depth of ditches 18-26 in.

French Drain Required: \_\_\_\_\_ Linear feet

Date: 12/22/2003

Inspected by: Raymond McSwain, S.  
Environmental Health Specialist

PERMIT NO. 19328

