HTE 04-5-8927

ARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

16918

OPERATIONS PERMIT

Name: (owner) Bernard Young

☑ New Installation ☑ Septic Tank

Property Location: SR# 1563 Bill Avery

☐ Repairs ☑ Nitrification Line

Subdivision Birchfield PH4

Lot # 17

Tax ID #

Quadrant #

Contractor: Bernard Young

Registration #

Basement with Plumbing: ☐ Garage: ☐

Water Supply: ☐ Well ☑ Public ☐ Community

Distance From Well: 50' ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: ☑ Conventional ☐ Other

Size of tank: Septic Tank: 1000 gallons Pump Tank: gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 18-24 in.

French Drain Required: – Linear feet

Date: 5-26-04

Inspected by: James E Manhart Jr
Environmental Health Specialist

PERMIT NO. 20766