

HTE 04-59016R

16599

# OPERATIONS PERMIT

Name: (owner) Danny Norris  New Installation  Septic Tank  
 Property Location: SR# 1141  Repairs  Nitrification Line  
 Subdivision Highland Forest Lot # 62  
 Tax ID # \_\_\_\_\_ Quadrant # \_\_\_\_\_  
 Contractor: Ted Brown Registration # \_\_\_\_\_

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: \_\_\_\_\_ ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional  Other Chamber Infiltrator Quick 4

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface Drainage Field No. of ditches 1 exact length of each ditch 150 ft. width of ditches 3 ft. depth of ditches 18-24 in.

French Drain Required: \_\_\_\_\_ Linear feet 1 chamber

Date: 09-15-04

Inspected by: Joe Wiles  
Environmental Health Specialist

PERMIT NO. 20425

