

HTE 04-5-9174

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Moss Home Builders & Realty  New Installation  Septic Tank  
 Property Location: SR# 2013 Avery Rd  Repairs  Nitrification Line

Subdivision DELLA LANE Lot # 2

Tax ID # \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 3 Lot Size: 3.3 acres

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other \_\_\_\_\_

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface Drainage Field No. of 4 exact length 100 width of \_\_\_\_\_ depth of \_\_\_\_\_  
 Ditches 3 of each ditch 133 ft. ditches 3 ft. ditches 20-18 in. <sup>max</sup>

French Drain Required: - Linear feet


Date: 4-20-04

This permit is subject to revocation if site plans or intended use change.

Signed: James E. Manhart <sup>RES</sup>  
 Environmental Health Specialist

4x100 MAX DEPTH OF TOP LINE IS 20" INCHES DEPTH.

3x133 - 18" inch DEPTH MAY.



#04-5-9174

# HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 20786. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

Moss Home Builders & Realty 910-893-4875  
Name Telephone #

P.O. Box 577 Lenoir N.C. 27546  
Address

Avery 2013 Avery 2013  
Property Location SR# Road Name

Dellalane 2 3 3.38  
Subdivision Lot # # Bedrooms Proposed Lot Size

### TYPE OF SYSTEM

New Installation  Repair  Septic Tank  Nitrification Lines

Conventional  Other \_\_\_\_\_

Basement  With Plumbing  Without Plumbing

Water Supply:  Well  Public Water Supply Minimum Well Setback: 50 Ft.

Septic Tank 1000 gal Pump Chamber \_\_\_\_\_ gal

### NITRIFICATION FIELD SPECIFICATIONS

Number of fields 2 # of lines per field 3 Length of lines 100 133 Ft.

Width of ditches 3 ft. Depth of ditches 20-18 inches

French Drain: Linear feet required \_\_\_\_\_ Depth of gravel \_\_\_\_\_

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

James E. Monahan 4-20-04  
Signature of Authorized Agent for Harnett County Date