

HTE 04-5-9378

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Denmark Homes Inc New Installation Septic Tank
 Property Location: SR# 1415 Rumbler Ch. Rd Repairs Nitrification Line

Subdivision Wyndham Place Lot # 23

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 25,000 ft²

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50 in ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other 25% Reduction System

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 80 ft. width of ditches 3 ft. depth of ditches 18-24 in.


French Drain Required: _____ Linear feet

Date: 6/1/2004

This permit is subject to revocation if site plans or intended use change.

Signed: [Signature]
 Environmental Health Specialist

* Maintain all setbacks



HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 20521. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

Denmark Homes Inc. Name 919 557 4377 Telephone #

1115 Oakridge Ducean Rd. Fuquay Varina NC 27526 Address

1415 Property Location SR# Ramsdell Church Road Name

Wyndham Place Subdivision 23 Lot # 3 # Bedrooms Proposed 25,000 ft² Lot Size

TYPE OF SYSTEM

New Installation Repair Septic Tank Nitrification Lines

Conventional Other 25% Reduction System

Basement With Plumbing Without Plumbing

Water Supply: Well Public Water Supply Minimum Well Setback: 50 Ft.

Septic Tank 1000 gal Pump Chamber _____ gal

NITRIFICATION FIELD SPECIFICATIONS

Number of fields 1 # of lines per field 3 Length of lines 80 Ft.

Width of ditches 3 ft. Depth of ditches 18-24 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

Bryan McLean R.S.
Signature of Authorized Agent for Harnett County

6/1/2004
Date