

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: D. Norow  
 Address:  
 Proposed Facility: 3BR Design Flow (.1949): 360  
 Location of Site:  
 Water Supply: HP  Public  Individual  Well  
 Evaluation Method:  Auger Boring  Pit  
 Type of Wastewater:  Sewage  Industrial Process

Applicant:  
 Date Evaluated: 6.28.04  
 Property Size:  
 Property Recorded:  
 Spring  Other

Profile #	1940 Landscape Position/Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1		0-30	SL	FR/GC	10YR 8/6				
		30-44	SCU	FR/GC	10YR 6/8	48	M/A	M/A	
2		0-36	SL	FR/GC	10YR 8/6				
		36-48	SCU	FR/GC	10YR 6/8				
3		0-48	SL	FR/GC	10YR 8/6				
4		0-36	SL	FR/GC	10YR 8/6				
		36-48	SCU	FR/GC	10YR 6/8				
5		0-36	SL	FR/GC	10YR 8/6				
		36-48	SCU	FR/GC	10YR 6/8				
6		0-36	SL	FR/GC	10YR 8/6				
		36-48	SCU	FR/GC	10YR 6/8				
7		0-30	SL	FR/GC	10YR 8/6				
		30-48	SCU	FR/GC	10YR 6/8				
8		0-48	SL	FR/GC	10YR 8/6				

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	Grass	LLP
Site LTAR	.6	.3

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948):  
 Evaluated By: [Signature]  
 Others Present: Holes by Steve


COMMENTS: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	NS-NON-STICKY SS-SLIGHTLY STICKY S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6		
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3		
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1		
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE  
 SG-SINGLE GRAIN  
 M-MASSIVE  
 CR-CRUMB  
 GR-GRANULAR  
 SBK-SUBANGULAR BLOCKY  
 ABK-ANGULAR BLOCKY  
 PL-PLATY  
 PR-PRISMATIC

MINERALOGY  
 SLIGHTLY EXPANSIVE  
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).




SITE PLAN APPROVAL

DISTRICT RA302 USE SFD

#BEDROOMS 3

Date 10/1/10 ADuggan  
Zoning Administrator



1x200  
18-30'

TED BROWN CONST. INC  
THE SAVANNAH II  
LOT# 110 HIGHLAND FOREST  
SCALE: 1"=40'

Permit Copy