


SITE/SOIL EVALUATION FOR ON-SIT WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES													
		1	2	3	4	5	6	7	8	9	10				
LANDSCAPE POSITION	.1940														
SLOPE (%)	.1940														
HORIZON 1 DEPTH		0-34	0-32	0-36	0-18										
Texture Group	.1941(A)(1)	LS	LS	SL	SL										
Consistence	.1941	Ufr	Ufr	Ufr	Ufr										
Structure	.1941(A)(2)	G	G	G	G										
Mineralogy	.1941(A)(3)	Ncd	Ncd	Ncd	Ncd										
HORIZON 2 DEPTH					14-24										
Texture Group	.1941(A)(1)				SL										
Consistence	.1941				G										
Structure	.1941(A)(2)				S&L										
Mineralogy	.1941(A)(3)				S&L										
HORIZON 3 DEPTH															
Texture Group	.1941(A)(1)														
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
HORIZON 4 DEPTH															
Texture Group	.1941(A)(1)														
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
SOIL WETNESS	.1942														
RESTRICTIVE HORIZON	.1944														
SAPROLITE	.1943/.1956														
CLASSIFICATION	.1948	S	S	S	PS										
LONG TERM ACCEPTANCE RATE	.1955	.8	.8	.8	.35										



Rd