

VIOLATION NOTICE

4

DO NOT REMOVE!

Harnett County Inspection Department
108 East Front Street • P.O. Box 65
Lillington, NC 27546
Phone: (910) 893-7525 Ext. 1 • Fax: (910) 893-2793

Job Name: _____ Date: _____

Address: _____

Lot No.: _____ Permit No.: _____

(Check Box for Violation)

- | | | | | | | | |
|-------------------------------------|-------------------------------------|----------------------------------|--|-------------------------------------|---------------------------------------|---------------------------------|--------------------------------------|
| <input type="checkbox"/> Footing | <input type="checkbox"/> Foundation | <input type="checkbox"/> Bldg. | <input type="checkbox"/> Elec. | <input type="checkbox"/> Plumb. | <input type="checkbox"/> Mech. | <input type="checkbox"/> Insul. | <input type="checkbox"/> Floor Fram. |
| <input type="checkbox"/> Floor Slab | <input type="checkbox"/> MFG. Home | <input type="checkbox"/> Modular | <input type="checkbox"/> Damp/Water Proof. | <input type="checkbox"/> Structural | <input type="checkbox"/> Wall Sheath. | <input type="checkbox"/> Other | |

Violations Found: _____

29 - Verify all truss repairs

30 - Need eng letter to state the # of truss referenced in the letter for the 4 ply repair.

31 - have not inspected the mech room due to possible re design.

32 - Need completion letter and repair on under minded footing in rear area.

* OK to insulate exterior walls

Code Enforcement Official

Signature: _____ Date: _____

It is unlawful for any subcontractor, general contractor, or owner to cover or cause to be covered any part of the work with flooring, sheetrock, earth or other material until the proper inspector had ample time to approve the installation