

# VIOLATION NOTICE

1

## DO NOT REMOVE!

### Harnett County Inspection Department

108 East Front Street • P.O. Box 65

Lillington, NC 27546

Phone: (910) 893-7525 Ext. 1 • Fax: (910) 893-2793

Job Name: \_\_\_\_\_ Date: \_\_\_\_\_

Address: 95 Centennial Pkwy

Lot No.: \_\_\_\_\_ Permit No.: \_\_\_\_\_

( Check Box for Violation )

- |                                     |                                     |                                  |  |                                     |                                       |                                 |                                      |
|-------------------------------------|-------------------------------------|----------------------------------|--|-------------------------------------|---------------------------------------|---------------------------------|--------------------------------------|
| <input type="checkbox"/> Footing    | <input type="checkbox"/> Foundation | <input type="checkbox"/> Bldg.   | <input type="checkbox"/> Elec.             | <input type="checkbox"/> Plumb.     | <input type="checkbox"/> Mech.        | <input type="checkbox"/> Insul. | <input type="checkbox"/> Floor Fram. |
| <input type="checkbox"/> Floor Slab | <input type="checkbox"/> MFG. Home  | <input type="checkbox"/> Modular | <input type="checkbox"/> Damp/Water Proof. | <input type="checkbox"/> Structural | <input type="checkbox"/> Wall Sheath. | <input type="checkbox"/> Other  |                                      |

Violations Found: 1- Right side storage room insulate pex at top plate  
2- Proper nail plate for A/C line set? (GA)  
3- Attach (all) toilet flanges  
4- Room 135 nail plate right rear corner at pex.  
5- Plumbing drain test not installed on slab plumbing  
6- Fine caulk top plate at dryer vent  
7- Truss B10 GA drilled for wire.  
8- Room 106 insulate pex at top plate.  
9- 107 Strap stud columns  
10- missing insulation depth ~~gauge~~ gauges  
11- Address proper nails in face hanger attached to two ply members

Code Enforcement Official

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

It is unlawful for any subcontractor, general contractor, or owner to cover or cause to be covered any part of the work with flooring, sheetrock, earth or other material until the proper inspector had ample time to approve the installation