



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

1/24/2022

**SUBJECT: ECOM2006-0008
ELECTRICAL COMMERCIAL**

To: CYPRESS CREEK RENEWABLES

Here are the results of all Inspections located at **555 NEILLS CREEK RD:**

Inspection Type: UNDERGROUND
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: UNDERGROUND
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: UNDERGROUND
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time:
Completed Date/Time:
Inspector: Brad Sutton
Result:
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: SLAB
Scheduled Date/Time: 2/11/2021
Completed Date/Time: 2/11/2021
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes: For transformer slab

Inspection Type: BONDING
Scheduled Date/Time: 2/18/2021
Completed Date/Time: 2/18/2021
Inspector: Brad Sutton
Result: APPROVED
Remarks:
Notes: DC trench west and Transformer pad ground ring

Inspection Type: UNDERGROUND
Scheduled Date/Time: 2/24/2021
Completed Date/Time: 2/24/2021
Inspector: Brad Sutton
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 2/22/2021 9:53 AM Daniel Andolsen
02/24/21 Afternoon , Underground Inspection
Contact Name: Daniel Andolsen
Site Address: 555 NEILLS CREEK RD
Phone: 2523735754
e-Mail: Dandolsen@watsonelec.com

Dc section trench west of pad. MV section from pad to first sectionalizer rear of site. Pictures to be uploaded of MV burial tape before final grade



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: BONDING
Scheduled Date/Time: 2/25/2021
Completed Date/Time: 2/25/2021
Inspector: Brad Sutton
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 2/22/2021 9:55 AM Daniel Andolsen
1:00pm - 3:00pm 02/25/21 Underground Inspection
Contact Name: Daniel Andolsen
Site Address: 555 NEILLS CREEK RD
Phone: 2523735754
e-Mail: Dandolsen@watsonelec.com

For transformer pad
Grounding/bonding and rebar mats for both pads

Inspection Type: UNDERGROUND
Scheduled Date/Time: 3/3/2021
Completed Date/Time: 3/3/2021
Inspector: Brad Sutton
Result: APPROVED
Remarks:
Notes: 3/2/2021 8:34 AM Daniel Andolsen
DC Underground inspection for tomorrow afternoon 2:00pm - 4:00pm
Contact Name: Daniel Andolsen
Site Address: 555 NEILLS CREEK RD
Phone: 2523735754
e-Mail: Dandolsen@watsonelec.com

South central DC conduits underground

Inspection Type: UNDERGROUND
Scheduled Date/Time: 3/4/2021
Completed Date/Time: 3/4/2021
Inspector: Brad Sutton
Result: APPROVED
Remarks:
Notes: 3/1/2021 3:44 PM Daniel Andolsen
DC Underground Inspection 10:00am - 12:00am
Contact Name: Daniel Andolsen
Site Address: 555 NEILLS CREEK RD
Phone: 2523735754
e-Mail: Dandolsen@watsonelec.com



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: DC trenches Far East and central line to near east

Scheduled Date/Time:

Inspection Type: UNDERGROUND

Scheduled Date/Time: 3/5/2021

Completed Date/Time: 3/5/2021

Inspector: Brad Sutton

Result: APPROVED

Remarks:

Notes: 3/1/2021 3:45 PM Daniel Andolsen
2:00pm - 4:00pm DC Underground Inspection
Contact Name: Daniel Andolsen
Site Address: 555 NEILLS CREEK RD
Phone: 2523735754
e-Mail: Dandolsen@watsonelec.com

East side complete dc trenches

Inspection Type: UNDERGROUND

Scheduled Date/Time: 3/10/2021

Completed Date/Time: 3/10/2021

Inspector: Deen Taylor

Result: APPROVED

Remarks: eTRAKiT Inspection Request

Notes: 3/9/2021 8:38 AM Daniel Andolsen
Final DC Underground Inspection 8:00am - 10:00am
Contact Name: Daniel Andolsen
Site Address: 555 NEILLS CREEK RD
Phone: 2523735754
e-Mail: Dandolsen@watsonelec.com

Inspection Type: ROUGH IN

Scheduled Date/Time: 3/22/2021

Completed Date/Time: 3/22/2021

Inspector: Brad Sutton

Result: APPROVED

Remarks:

Notes: West strings and main inverters terminations



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: ROUGH IN
Scheduled Date/Time: 3/30/2021
Completed Date/Time: 3/30/2021
Inspector: Brad Sutton
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 3/26/2021 1:40 PM Daniel Andolsen
Grounding Inspection
Contact Name: Daniel Andolsen
Site Address: 555 NEILLS CREEK RD
Phone: 2523735754
e-Mail: Dandolsen@watsonelec.com

Inspection Type: FINAL**
Scheduled Date/Time: 4/1/2021
Completed Date/Time: 4/1/2021
Inspector: Brad Sutton
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 3/26/2021 1:41 PM Daniel Andolsen
Final Electrical Inspection
Contact Name: Daniel Andolsen
Site Address: 555 NEILLS CREEK RD
Phone: 2523735754
e-Mail: Dandolsen@watsonelec.com