



**Harnett County**  
108 EAST FRONT STREET  
LILLINGTON, NC 27546  
Phone:  
Fax:

11/17/2020

**SUBJECT: ECOM2009-0010  
ELECTRICAL COMMERCIAL**

To: Site Dev Inc.

Here are the results of all Inspections located at **503 CALVARY CHURCH RD:**

Inspection Type: UNDERGROUND  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Scott Guy  
Result:  
Remarks:  
Notes:

Inspection Type: ROUGH IN  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Scott Guy  
Result:  
Remarks:  
Notes:

Inspection Type: FINAL\*\*  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Scott Guy  
Result:  
Remarks:  
Notes:

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 11/13/2020  
Completed Date/Time: 11/13/2020  
Inspector: Scott Guy  
Result: DISAPPROVED  
Remarks:

Notes: gate code is 1760 if any question or need assistance call Brenda at 469-338-7618  
Water running out of electrical conduit elbow of cabinet next to generator.