



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

10/12/2021

**SUBJECT: ECOM2101-0015  
ELECTRICAL COMMERCIAL**

To: Tillman Infrastructure LLC

Here are the results of all Inspections located at **161 RED HILL CHURCH RD:**

Inspection Type: OVERHEAD  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:

Inspection Type: RE-CONNECT  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:

Inspection Type: TEMP POWER CERTIFICATION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:

Inspection Type: UNDER SLAB  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:



**Harnett County**  
420 Mckinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: FINAL\*\*  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:

Inspection Type: UNDERGROUND  
Scheduled Date/Time: 7/12/2021  
Completed Date/Time: 7/12/2021  
Inspector: Deen Taylor  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: ROUGH IN  
Scheduled Date/Time: 9/9/2021  
Completed Date/Time: 9/9/2021  
Inspector: Deen Taylor  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 9/15/2021  
Completed Date/Time: 9/15/2021  
Inspector: Brad Sutton  
Result: DISAPPROVED  
Remarks:

Notes: Engineered plan calls for 2 sets of 500 kcmil parallel service entrance conductors. Single set of 2/0 aluminum installed from 25 KVA transformer.  
All work from the service disconnects to equipment is approved.  
Proved a letter from the design engineer of record on the service entrance conductors as being suitable for the installation.



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 10/8/2021  
Completed Date/Time: 10/8/2021  
Inspector: Brad Sutton  
Result: APPROVED  
Remarks:  
Notes:

After speaking to the Duke Energy engineer, I am informed that they can do whatever they want, regardless of the plan engineers design. This approval is for the electrical contractors work only.