

APPENDIX C1

STATEMENT OF SYSTEM COMMISSIONING

Part 1: Mechanical

Project Name: CFVH HARNETT MOB - Tenant Fit-Up

Project Location: 225 Brightwater Drive, Lillington, NC 27546


In my professional opinion, the HVAC systems have been installed in substantial compliance with the intent of the approved project plans and specifications based on a site observation performed and upon review of the following:

YES	NO	NOT REQUIRED	ITEMS	COMMENTS
X			Testing and Balance Reports	
X			Operations and Maintenance Manuals for HVAC	
X			HVAC Equipment	
X			HVAC Controls and Operational Sequences	

Notes: _____

List of Deferred Tests: _____

Name: Dane Wallin
Signature: *Dane Wallin*
Date: 2024-10-29



Seal Above:

Part 2: Service Water Heating

Project Name: CFVH HARNETT MOB - Tenant Fit-Up

Project Location: 225 Brightwater Drive, Lillington, NC 27546

In my professional opinion, the service water heating systems have been installed and are in substantial compliance with the intent of the approved project plans and specifications based on a site observation performed and upon review of the following:

YES	NO	NOT REQUIRED	ITEMS	COMMENTS
X			Manuals for Service Water Heating	
X			Service Water Heating Systems	


Notes: _____

List of Deferred Tests: _____

Name: Dane Wallin

Signature: *Dane Wallin*

Date: 2024-10-29



Seal Above:

Part 3: Electrical

Project Name: CFVH HARNETT MOB - Tenant Fit-Up

Project Location: 225 Brightwater Drive, Lillington, NC 27546

In my professional opinion, the lighting systems have been installed and are in substantial compliance with the intent of the approved project plans and specifications based on a site observation performed and upon review of the following:

YES	NO	NOT REQUIRED	ITEMS	COMMENTS
X			Manuals for Lighting Systems	
X			Lighting Equipment	Approved, contingent on notes below
		X	Lighting Controls and Operational Sequences	

Notes: CT room 1217 emergency egress lighting fixture was not installed. Lighting equipment will be approved once this is installed and confirmed to come on in 10 seconds in the event of loss of utility power.

List of Deferred Tests:

Name: Jesse Alonzo Jr

Signature: *Jesse Alonzo Jr*

Date: 2024-10-29



Seal Above: