



# Permit Inspections

## Harnett County

Permit Number: **ECOM2402-0003**

Description: **2 Story Storage Building w/livable area**

Applied: **2/9/2024**

Approved: **2/9/2024**

Site Address: **14396 NC 210 S**

Issued: **2/26/2024**

Finalized:

City, State Zip Code: **SPRING LAKE, NC 28390**

Status: **ISSUED**

Applicant: **Germana Sylvie**

Parent Permit: **BCOM2307-0004**

Owner: **C/O RELIANT REAL ESTATE MANAGEMENT LLC**

Parent Project:

Contractor: **Reliant Development LLC**

Details:

### LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			OVERHEAD	James T Hall		
Notes:						
			TEMP POWER CERTIFICATION	James T Hall		
Notes:						
			FINAL**	James T Hall		
Notes:						
	4/9/2024	4/9/2024	T-POLE	James T Hall	DISAPPROVED	
Notes:						
Please call Tim Denzler at 516-537-2324 before going out.						
Need 2 circuits and weather proof bubble covers with wires in conduit						
	5/31/2024	5/31/2024	T-POLE	James T Hall	APPROVED	
Notes:						
	11/12/2024	11/12/2024	UNDERGROUND	James T Hall	APPROVED	
Notes:						
would like afternoon if possible						
	2/19/2025	2/19/2025	ROUGH IN	James T Hall	APPROVED	
Notes:						
partial rough in for the electrical and the elevator machine room						
Apartment Only						
	4/1/2025	4/1/2025	ROUGH IN	James T Hall	APPROVED	
Notes:						
For the office						
Please Call Greg Douglas 470.717.4111						
Office only						