



# Permit Inspections

## Harnett County

**Permit Number: ECOM2503-0008**

**Description: 60 amp service for Spectrum Cable (Fiber Optics)**

**Applied: 3/11/2025**

**Approved: 3/11/2025**

**Site Address: 17 ALLWOOD DR**

**Issued: 3/11/2025**

**Finaled: 4/29/2025**

**City, State Zip Code: FUQUAY-VARINA, NC 27526**

**Status: FINALED**

**Applicant: AJ's Electrical Services LLC**

**Parent Permit:**

**Owner: Charter Communications**

**Parent Project:**

**Contractor: AJ's Electrical Services LLC**

**Details:**

### LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
	4/11/2025	4/11/2025	FINAL**	Brad Sutton	DISAPPROVED	
Notes: Install 2 ground rods at least 6 feet apart. Bond GEC to neutral in meter base or main disconnect. Leave all open for inspection						
	4/22/2025	4/22/2025	FINAL**	Justin Ryan McLeod	DISAPPROVED	
Notes: Same as before. Only see 1 ground rod about 4-5' behind the pole and appears the Grounding conductor goes under pad then comes back up and is coiled up laying on pad left of meter base						
	4/29/2025	4/29/2025	FINAL**	Justin Ryan McLeod	APPROVED	
Notes:						