30450

HTE#			

Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: SK 1500 Beason RD SUBDIVISION NEW Site Improvements required prior to Construction Authorization Issuance: Type of Structure: Proposed Wastewater System Type: 25% REPSULATION Projected Daily Flow: 360 GPD Number of Occupants: 6 Number of bedrooms: 3 Basement Yes May be required based on final location and elevations of facilities Pump Required: ☐Yes ☐ No Type of Water Supply:

Community Public Well Distance from well 50 feet Permit valid for: Permit conditions: ■ No expiration The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit... **Construction Authorization** (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance ISSUED TO: HUNTER BACKBURN PROPERTY LOCATION: SO 1500 BENSON RD SUBDIVISION Repair ☐ New ☐ Expansion Type of Wastewater System** (Initial) Wastewater Flow: 360 GPD (See note below, if applicable 259, 125 DUCTION Installation Requirements/Conditions Number of trenches ____ Z Exact length of each trench 120 Septic Tank Size Fr gallons Pump Tank Size gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 18-28 (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ______ft. TDH vs. ____ GPM Conditions: WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent: Manhard Willes Date: 5-20-15 Construction Authorization Expiration Date: 5-20-24

HTE# BAES 1808-0015

Harnett County Department of Public Health Site Sketch

	PROPERTY LOCATON: SIL 1500	Benson 1	20	
ISSUED TO: HUNTER BOOKBURN	SUBDIVISION			LOT #
Authorized State Agent: Zanes E/	Marshan franksis	Date:	5-20-19	

