


Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Cynthia McKoy PROPERTY LOCATION: 4195 McNeill Rd.
 SUBDIVISION Hunters Pointe LOT # 5
 NEW REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance:
 Type of Structure: Existing 3-bedroom MH
 Proposed Wastewater System Type: 25% Reduction System
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well 50 feet Permit valid for: Five years
 No expiration
 Permit conditions: _____

Authorized State Agent:  Date: 04/10/2019 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Cynthia McKoy PROPERTY LOCATION: 4195 McNeill Rd.
 SUBDIVISION Hunters Pointe LOT # 5
 Facility Type: Existing 3-bedroom MH New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** Not Applicable (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable
25% Reduction System (Repair)
 Installation Requirements/Conditions
 Septic Tank Size Ext. gallons Exact length of each trench 75 feet Trench Spacing: 9 Feet on Center
 Pump Tank Size _____ gallons Trenches shall be installed on contour at a Soil Cover: 10 inches
 Maximum Trench Depth of: 22 inches (Maximum soil cover shall not exceed
 (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom)
 in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: NA inches below pipe
NA inches above pipe
NA inches total
 Conditions: 50ft Well Setback; 300ft conv. permissible if available space; PVC tee/filter added req.

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
 Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent:  Date: 04/10/2019
ANDREW CURRAN Construction Authorization Expiration Date: 04/10/2024


HTE# EH1902-0011

Permit # N/A

Harnett County Department of Public Health Site Sketch

ISSUED TO: Cynthia Deloris McKay PROPERTY LOCATOR: 4195 McNeill Rd (SR 1224)
SUBDIVISION: Huntress Pointe LOT # 5

Authorized State Agent: Andrew Curran Date: 04/10/2019



- * 50FT EXT well setback
- * EXT WATER AND POWER SHALL BE LOCATED PRIOR TO INSTALL
- * 10FT WATER LINE SETBACK [MAY REQUIRE RELOCATION]
- * D-BOX MAY REQ. REPLACEMENT
- * 300FT CONVENTIONAL IF AVAILABLE SPACE
- * TANK SHALL BE UNCOVERED, PUMPED AND INSPECTED W/ AFFLUENT FILTER AND
- EXISTING WELL PVC TEE ADDED

MCNEILL RD (SR 1224)