[] Re-evaluation _	
2	(number)

DENR 3765 (Revised 2/2011)

On-Site Wastewater Section (Review 12/2010)

North Carolina Department of Environment and Natural Resources Division of Environmental Health

PREOCCUPANCY EVALUATION REPORT OF DRINKING WATER SUPPLY AND WASTEWATER FACILITIES FOR MIGRANT HOUSING

On <u>62/26/2019</u> , as required in G.S. 95-225(c	c) and (d), an evaluation was conducted of the drinking water supply and
(date)	osed of # of Mobile home units, # of House (s) and
Other type of housing/describe:	located at 5681 619 02 421
Lillington, DC 27546 and	pperated byMuffle Allen
of 250 Auty Rd. Lilligton, DC	(name of person[s]/company)
*** PLEASE SUBMIT ONE	(mailing address) REPORT FOR EACH SEPTIC SYSTEM ***
This report describes well/springl and sewage (number) The findings of this evaluation are as follows:	e system (Use reverse for a drawing, if needed.)
WATER SUPPLY	
(yes/no) Community or non-transient-non-communit Division of Environmental Health Private Water or Non-Community System (yes/no)	y water system under routine surveillance of Public Water Supply Section,
At the time of inspection, there was son wisual endowed was not) 15A NCAC 18A .1700 (attach copy of bacteriological sample)	evidence of non-compliance with the "Protection of Water Supplies" ple). List deficiencies which were identified:
7.	(Use reverse if necessary)
WASTEWATER FACILITIES	
(subject/not subject)	ICAC 18A .1900, "Laws and Rules for Sewage Treatment and Disposal
On-Site Septic Tank System [] Chemical Portable To	ilets [] Others [] Privy(ies)
(was/was not)	al evidence of non-compliance with 15A NCAC 18A .1900 (including
.1962) "Laws and Rules for Sewage Treatment and Dispos	sal System." List deficiencies which were identified:
	Use reverse if necessary)
The wastewater system, to the best of my knowledge and I	(maximum number)
Environmental Health Specialist	Harnett County Environmental Health
v e	Health Department
03/05/2019 Date	307 W. Cornelius Harnett Blvd.
	Address
Forward copies to: Migrant Housing Operator Department of Labor	Lillington, NC 27546
Agriculture Safety & Health Bureau	910-893-7547
	Office Phone Number



North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology **Certificate of Analysis**

http://slph.ncpublichealth.com

4312 District Drive MSC 1918

Phone: 919-733-7308 Fax: 919-715-8611

Raleigh, NC 27699-1918

FINAL REPORT

Report to: ANDREW CURRIN

HARNETT CO ENVIRONMENTAL HEALTH

307 CORNELIUS HARNETT BLVD

Lillington, NC 27546

Name of System:

Matthew Allen

5681 Old US 421

Lillington, NC 27546

EIN: 566000306EH

Delivery: NC Courier

12:30

Bv:

Harnett County

StarLiMS ID: ES190227-0079

Date Collected: Date Received: 02/26/2019 02/27/2019 Time Collected:

Andrew Currin

Sample Source:

Well water

Sampling Point:

Well Permit No.

Well head

Time Received:

09:03

Bv:

Angela Heybroek

Sample Type:

GPS No.

EH1902-0012

Comment

Treatment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			02/27/2019
E. coli	Absent			02/27/2019

Report Date:

03/04/2019

Reported By:

Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are Absent, the water is considered safe for drinking purpose. If coliform bacteria are Present, the water is considered unsafe for drinking purpose. Presence of E. coli (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.

North Carolina Division of Public Health Occupational and Environmental Epidemiology Branch, Epidemiology Section BIOLOGICAL ANALYSIS REPORT

Private well water information and recommendations
County: Hargett Name: Matthew Allen Sample ID Number: Location: 5681 old US 421 Reviewer Andrew Currin, MEHS Lillington, >c 27546 Initial Sample Confirmation Sample
BIOLOGICAL ANALYSIS RESULTS AND RECOMMENDATIONS FOR USES OF YOUR PRIVATE WELL WATER (These recommendations are based on biological analysis only.)
No coliform bacteria were found in your well water. Your water can be used for all purposes including drinking, cooking, washing dishes, bathing and showering.
Total coliform bacteria were detected in the sample which indicates that harmful bacteria from human or animal waste could enter the well. Do not use the water for drinking or cooking unless it has been boiled for 3 minutes. You may use your water for all other purposes including washing dishes, bathing or showering. Your well water needs to be re-tested to verify that the result is accurate.
Fecal coliform bacteria were detected in the sample. Do not use the water for drinking, cooking, washing dishes, bathing or showering.

If the re-test shows contamination by bacteria contact your local health department for assistance. There may be a problem with the construction of the well, the groundwater source, or operation of the well. The well needs to be inspected by the local health department or a local well contractor to determine the problem with the well and to give guidance on how to correct the problem.

Your well water was tested for biological contaminants (total coliform and fecal coliform bacteria). The results were evaluated using the federal drinking water standards.

Drinking water may contain substances that can occur naturally in water or can be introduced into water from man-made sources. Total coliform bacteria are found in soil and fecal coliform bacteria are found in animal and human waste. Total coliform or fecal coliform bacteria in well water indicate that the well may have structural problems or that the well was not properly disinfected.

If you have been drinking the well water and are pregnant, nursing, have a child in the household under 5 years of age, or immunocompromised (such as an individual with AIDS, cancer, hepatitis, dialysis or surgical procedures) inform your physician of these results at your next visit.

If the contamination continues, you should investigate the possibility of drilling a new well or installing a point-of-entry disinfection unit which can use chlorine, ultraviolet light, or ozone.

For further information please contact your county health department or the Occupational and Environmental Epidemiology Branch at 919-707-5900.