

HTE# _____

Harnett County Department of Public Health

30408

Improvement Permit

Judith Bingham A building permit cannot be issued with only an Improvement Permit
 ISSUED TO: ~~James E. Markham~~ PROPERTY LOCATION: 140 POND SWING LN
 SUBDIVISION _____ LOT # _____
 NEW REPAIR EXPANSION
 Type of Structure: EX SFD Site Improvements required prior to Construction Authorization Issuance: _____
 Proposed Wastewater System Type: _____
 Projected Daily Flow: 480 GPD
 Number of bedrooms: 4 Number of Occupants: 8 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well 50' feet Permit valid for: Five years
 No expiration
 Permit conditions: _____

Authorized State Agent: *James E. Markham* Date: 3-7-17 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Judith Bingham PROPERTY LOCATION: 140 POND SWING LN
 SUBDIVISION _____ LOT # _____
 Facility Type: EX SFD New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** _____ (Initial) Wastewater Flow: 480 GPD
 (See note below, if applicable _____)

Installation Requirements/Conditions
 Septic Tank Size 1200 gallons Exact length of each trench _____ feet Trench Spacing: _____ Feet on Center
 Pump Tank Size _____ gallons Trenches shall be installed on contour at a Soil Cover: _____ inches
New Maximum Trench Depth of: _____ inches (Maximum soil cover shall not exceed 36" above the trench bottom)
 (Trench bottoms shall be level to +/- 1/4" in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM _____ inches below pipe
 Aggregate Depth: _____ inches above pipe
 Conditions: NEW TANK ONLY - CALL BEFORE INSTALLING NEW TANK _____ inches total

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

***If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.*

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: *James E. Markham* Date: 3-7-18
 Construction Authorization Expiration Date: 3-7-24

HTE# _____

Permit # 30408


Harnett County Department of Public Health Site Sketch

ISSUED TO: Judith Beaman PROPERTY LOCATOR: 140 Pouch Spring LN
SUBDIVISION _____ LOT # _____

Authorized State Agent: James E. Manhart ~~PERMITS~~ Date: 3-7-19

* NEW TANK ONLY

* CALL BEFORE INSTALL OF TANK



Pouch Spring LN