

April 10th, 2019

Kenneth Johnson
350 Josie Drive
Benson, NC 27504

RE: Repair Application # EH1904-0002

Mr. Johnson,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover Outlet lid on septic tank and break seal (\$25.00 fee incurred).

2. **Have system pumped out**

3. Replace Sanitary T

4. **Other – Tank Backing up. No surfacing present. Prior to progressing with system repair, uncover d-box, clean out d-box, and attempt to suction out drain lines. Reconfirm with EH if problems persist.**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin R.E.H.S
Environmental Health Specialist

Harnett County Department of Public Health

AC/kh
Copy - Central Permitting