

May 7th, 2019

Jim Mohler  
Po Box 48146  
Cumberland, NC 28331

**RE: Septic System Application for Repair: 86 Lansing Ct**

Dear Mr. Mohler,

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank and break seal.
- 2. Have system pumped out
- 3. Replace sanitary T
- 4. Other – **French drain shall be verified open at back right corner of property prior to repair evaluation. Drain shall be opened and allowed adequate time to drain properly.**

If you have any questions I can be reached at 910-893-7547 between 8-9 am. Reconfirm when lot is ready.

Sincerely,



Andrew Currin, R.E.H.S.  
Environmental Health Specialist  
Harnett County Department of Public Health

AC/kh  
Copy - Central Permitting