

May 31st, 2019

Karen Mahr
230 Wyndham Place Dr
Fuquay Varina, NC 27526

RE: Septic System Application for Repair: 230 Wyndham Place Dr

Dear Mrs. Mahr,

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank and break seal.
- 2. Have system pumped out
- 3. Replace sanitary T
- 4. Other – **No repair required at time of inspection. Drainfield area clear of any surface affluent, d-box empty and clear, tank pumped and in operational order. Failure must be noted to require system repair.**

If you have any questions I can be reached at 910-893-7547 between 8-9 am.

Sincerely,



Andrew Currin, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/kh
Copy - Central Permitting