



North Carolina State Laboratory of Public Health
Environmental Sciences
Inorganic Chemistry

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918

http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

Certificate of Analysis

FINAL REPORT

Report to: Environmental Health

Name of System:

HARNETT CO ENVIRONMENTAL HEALTH
 307 CORNELIUS HARNETT BLVD
 LILLINGTON, NC 27546

Robert & Wendy Giuliano
 194 Country Meadow Ln
 Coats, NC 27521

EIN: 566000306EH

Delivery: NC Courier

StarLiMS ID: **ES190604-0044**

Date Collected: 06/03/2019

Time Collected: 16:00

By: J. E Manhart III

Date Received: 06/04/2019

Time Received: 07:50

Sample Type: Raw

Sampling Point: Well head

Well Permit No.

Sample Source: Well water

Receipt Temp. :

GPS Number:

Profile: Inorganic Chemical + Metals I

Analyte	Test Result	Allowable Limit	Unit	Qualifier(s)
Arsenic	<0.005	0.010	mg/L	
Barium	<0.1	2.0	mg/L	
Cadmium	<0.001	0.005	mg/L	
Calcium	21		mg/L	
Chloride	<5	250	mg/L	
Chromium	<0.01	0.10	mg/L	
Copper	<0.05	1.3	mg/L	
Fluoride	<0.2	4.00	mg/L	
Iron	0.18	0.30	mg/L	
Lead	<0.005	0.015	mg/L	
Magnesium	8		mg/L	
Manganese	0.23	0.05	mg/L	
Mercury	<0.0005	0.002	mg/L	
pH	7.9		N/A	
Selenium	<0.005	0.05	mg/L	
Silver	<0.05	0.10	mg/L	
Sodium	13.9		mg/L	
Sulfate	<5	250	mg/L	
Total Alkalinity	108		mg/L	
Total Hardness	86		mg/L	
Zinc	0.38	5.00	mg/L	

Report Date: 06/18/2019

Reported By:

Cindy Price

Cindy Price