


CERTIFICATE OF COMPLETION / OPERATIONAL PERMIT

Name: (owner) Carrin Builders Inc New Installation Septic Tank
 Property Location: SR# 1446 Repairs Nitrification Line
 Subdivision Wexford Lot # 5
 Contractor: Carrin Builders Inc Registration # 34
 Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: 50+ ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____
 Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface Drainage Field No. of ditches 2 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 18-22 in.
 French Drain: _____ Linear feet

PERMIT NO. 8019 Date: 11-24-93
 Inspected by: Thomas J. Boye
 Environmental Health Specialist



IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Carrin Builders New Installation Septic Tank
 Property Location: SR# 1446 Repairs Nitrification Line

Subdivision Wexford Lot # 5

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: 2 Lot Size: .469

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: NA ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 2 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 18-22 in.

French Drain required: _____ Linear feet


This permit is subject to revocation if site plans or intended use change.

Date: 10-6-93

Signed: Thomas J. Boyce

Environmental Health Specialist

VOID AFTER 5 YEARS



Maintain setbacks
 5' from house
 10' from property line
 Install on contour