

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

ph: 910-893-7547  
fax: 910-893-9371

July 18th, 2019

Jonathan Peake  
411 Valley Oak Drive  
Bunnlevel, NC 28323

**RE: Septic System Application for Repair: 102 Stonecliff Lane, Sanford**

Dear Mr. Peake,

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover outlet lid on septic tank and break seal.

2. Have system pumped out

3. Replace sanitary T

**4. Other – No failure located. Tank not uncovered. D-Box not full. No backing up of affluent seen. No surfacing of sewage found. Routine system maintenance advised to clean out d-box and ensure drainlines are clear of obstructions. Application mentioned septic inspection. Septic inspection shall be provided to Health Department if new drainline or system is requested. Additionally, septic tank shall be uncovered for full inspection if permit is requested.**

If you have any questions I can be reached at 910-893-7547 between 8-9 am.

Sincerely,



Andrew Currin, R.E.H.S.  
Environmental Health Specialist  
Harnett County Department of Public Health

AC/kh  
Copy - Central Permitting