

Harnett County Department of Public Health Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: GEORGE + TINA DUTTON PROPERTY LOCATION: 199 DEXTERFIELD DR. (CHALBEATE RD) ^{SL 1129}
 SUBDIVISION: DEXTERFIELD LOT # 21
 NEW REPAIR EXPANSION
 Type of Structure: 3-BEDROOM EXT SIS
 Proposed Wastewater System Type: EXT 25% RED.
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well NA feet
 Permit valid for: Five years No expiration
 Permit conditions: _____

Authorized State Agent: [Signature] Date: 10/01/2020 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules 1950, 1952, 1954, 1955, 1956, 1957, 1958, and 1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: GEORGE + TINA DUTTON PROPERTY LOCATION: 199 DEXTERFIELD DR. (CHALBEATE RD) ^{SL 1129}
 SUBDIVISION: DEXTERFIELD LOT # 21
 Facility Type: EXT 3-BD SIS New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** EXT 25% REDUCTION SIS. (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable
SPLIT 25% RED. (EXT) (Repair)

Installation Requirements/Conditions

Septic Tank Size <u>EXT</u> gallons	Number of trenches <u>EXT</u>	Exact length of each trench <u>EXT</u> feet	Trench Spacing: <u>EXT</u> Feet on Center
Pump Tank Size _____ gallons	Trenches shall be installed on contour at a	Maximum Trench Depth of: <u>EXT</u> inches	Soil Cover: <u>EXT</u> inches
	(Trench bottoms shall be level to +/-1/4" in all directions)	(Maximum soil cover shall not exceed 36" above the trench bottom)	

Pump Requirements: _____ ft. TDH vs. _____ GPM
 Aggregate Depth: EXT inches below pipe
EXT inches above pipe
EXT inches total

Conditions: PROPERTY LINE CURTAIN DRAIN INSTALL ONLY

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 10/01/2020
ANDREW COLVIN Construction Authorization Expiration Date: 10/01/2025

Application # EH 1907-0008


Harnett County Department of Public Health Site Sketch

Property Location: 199 DEXTERFIELD DR. (CHAUBEATE RD. - S/L 1429)

Issued To: GEORGE + TINA DUTTON Subdivision DEXTERFIELD Lot # 21

Authorized State Agent: [Signature] Date: 10/01/2020
ANDREW COLLINS

- * CURTAIN DRAIN ALONG PROPERTY LINE
- * PLASTIC ALONG DOWNHILL SIDE
- * PIPE SHALL BE PLACED AT BASE
- * HOMEOWNER ASSOCIATED APPROVED VIA EMAIL WATER LAMP DAYLIGHT INTO STREET [ATTACHED]
- * OWNER AWARE THAT CURTAIN DRAIN DOES NOT GUARANTEE TO FIX PROBLEM DUE TO COMPOUNDING VARIABLES [LATERAL WATER, SFS. AGE, BLOCKAGES, ETC.]



RECOMMENDATION

- * IMPORT ADDITIONAL SOIL
COVER IN SHALLOW MEA
AT FAR END OF SFD
WHERE WATER SURFACES

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.