

Harnett County Department of Public Health Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Team Harris Real Estate PROPERTY LOCATION: 87 Surfwind Dr. (Elliot Bridge Rd.)
 SUBDIVISION: Tradewinds LOT # 133
 NEW REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance:
 Type of Structure: Ext SFD
 Proposed Wastewater System Type: Ext System
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well NA feet Permit valid for: Five years
 Permit conditions: No expiration

Authorized State Agent: [Signature] Date: 08/26/2019 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization (Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Team Harris Real Estate PROPERTY LOCATION: 87 Surfwind Dr. (Elliot Bridge Rd.)
 SUBDIVISION: Tradewinds LOT # 133
 Facility Type: Ext SFD New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** Existing System (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable)
Existing repair (Repair)
 Installation Requirements/Conditions
 Septic Tank Size 1000 gallons [NEW] Number of trenches Ext
 Pump Tank Size _____ gallons Exact length of each trench Ext feet Trench Spacing: Ext Feet on Center
 Trenches shall be installed on contour at a Soil Cover: Ext inches
 Maximum Trench Depth of: Ext inches (Maximum soil cover shall not exceed
 (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom)
 in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: Ext inches below pipe
 _____ inches above pipe
 _____ inches total

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
 Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 08/26/2019
Andrew Curran Construction Authorization Expiration Date: 08/26/2024


HTE# EH1908-0009

Permit # NA

Harnett County Department of Public Health Site Sketch

ISSUED TO: Team Harris Real Estate PROPERTY LOCATOR: 87 Surfwind Dr. (Elliot Bridge Rd.)
SUBDIVISION Tradewinds LOT # 133

Authorized State Agent: *Andrew Curran* Date: 08/26/2019
ANDREW CURRAN



* TANK REPLACEMENT ONLY
- TANK SHALL BE PUMPED,
CLOSED, AND BACKFILLED
ONSITE
* THIS DRAWING IS FOR
ILLUSTRATIVE PURPOSE
ONLY, SYSTEM INSTALLATION
MUST MEET ALL PERTINENT
LAWS, RULES, AND REGULATIONS

SURFWIND DRIVE