

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: _____ Applicant: _____
 Address: _____ Date Evaluated: **9/10/09**
 Proposed Facility: _____ Design Flow (.1949): **360 gpd** Property Size: _____
 Location of Site: _____ Property Recorded: _____
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 5-7	0-48	GS	VF2 NS/NP					S .8
2		0-48	GS	VF2 NS/NP					S .8

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): 3
Available Space (.1945)		<input checked="" type="checkbox"/>	Evaluated By: OS
System Type(s)		Imp 25% Q60	Others Present: -
Site LTAR		.7	

