

Evaluation
 Re-evaluation _____
(number)

North Carolina Department of Environment and Natural Resources
Division of Environmental Health
**PREOCCUPANCY EVALUATION REPORT
OF DRINKING WATER SUPPLY AND
WASTEWATER FACILITIES FOR MIGRANT HOUSING**

On 12/17/19, as required in G.S. 95-225(c) and (d), an evaluation was conducted of the drinking water supply and wastewater system serving a migrant housing site composed of # of _____ Mobile home units, # of 1 House (s) and

Other type of housing/describe: _____ located at 164 Del Toro Ln
Lillington (address or directions; use reverse if needed)
and operated by Jimmy Autry
(name of person[s]/company)
of 164 Del Toro Ln, Lillington NC 27546
(mailing address)

***** PLEASE SUBMIT ONE REPORT FOR EACH SEPTIC SYSTEM *****

This report describes well/spring 1 and sewage system 1. (Use reverse for a drawing, if needed.)
(number) (number)

The findings of this evaluation are as follows:

WATER SUPPLY

NO Community or non-transient-non-community water system under routine surveillance of Public Water Supply Section,
(yes/no) Division of Environmental Health
YES Private Water or Non-Community System
(yes/no)

At the time of inspection, there was not visual evidence of non-compliance with the "Protection of Water Supplies"
(was/was not)

15A NCAC 18A .1700 (attach copy of bacteriological sample). List deficiencies which were identified:

(Use reverse if necessary)

WASTEWATER FACILITIES

System subject to approval under 15A NCAC 18A .1900, "Laws and Rules for Sewage Treatment and Disposal
(subject/not subject)
Systems." Explain, if not subject to approval _____

On-Site Septic Tank System Chemical Portable Toilets Others _____ Privy(ies) _____

At the time of inspection, there was not visual evidence of non-compliance with 15A NCAC 18A .1900 (including
(was/was not)
.1962) "Laws and Rules for Sewage Treatment and Disposal System." List deficiencies which were identified:

(Use reverse if necessary)

The wastewater system, to the best of my knowledge and belief, is sized to serve 8 people.
(maximum number)

Brittany Adams BAH REHS **Harnett County Environmental Health**
Environmental Health Specialist Health Department

12/17/19
Date

307 W. Cornelius Harnett Blvd.
Address

Forward copies to: Migrant Housing Operator
Department of Labor
Agriculture Safety & Health Bureau

Lillington, NC 27546

910-893-7547

Office Phone Number

Evaluation
 Re-evaluation _____
(number)

North Carolina Department of Environment and Natural Resources
Division of Environmental Health
**PREOCCUPANCY EVALUATION REPORT
OF DRINKING WATER SUPPLY AND
WASTEWATER FACILITIES FOR MIGRANT HOUSING**

On 12/17/19, as required in G.S. 95-225(c) and (d), an evaluation was conducted of the drinking water supply and
(date)

wastewater system serving a migrant housing site composed of # of _____ Mobile home units, # of 1 House (s) and

Other type of housing/describe: _____ located at 5849 NC 200 S
(address or directions; use reverse if needed)

Bunnlevel and operated by Jimmy Autry
(name of person(s)/company)

of 5849 NC 210 S, Bunnlevel NC 28323
(mailing address)

***** PLEASE SUBMIT ONE REPORT FOR EACH SEPTIC SYSTEM *****

This report describes well/spring 0 and sewage system 1. (Use reverse for a drawing, if needed.)
(number) (number)

The findings of this evaluation are as follows:

WATER SUPPLY

YES Community or non-transient-non-community water system under routine surveillance of Public Water Supply Section,
(yes/no) Division of Environmental Health

NO Private Water or Non-Community System
(yes/no)

At the time of inspection, there was not visual evidence of non-compliance with the "Protection of Water Supplies"
(was/was not)

15A NCAC 18A .1700 (attach copy of bacteriological sample). List deficiencies which were identified:

(Use reverse if necessary)

WASTEWATER FACILITIES

System subject to approval under 15A NCAC 18A .1900, "Laws and Rules for Sewage Treatment and Disposal
(subject/not subject)

Systems." Explain, if not subject to approval _____

On-Site Septic Tank System Chemical Portable Toilets Others _____ Privy(ies) _____

At the time of inspection, there was not visual evidence of non-compliance with 15A NCAC 18A .1900 (including
(was/was not)

.1962) "Laws and Rules for Sewage Treatment and Disposal System." List deficiencies which were identified:

(Use reverse if necessary)

The wastewater system, to the best of my knowledge and belief, is sized to serve 16 people.
(maximum number)

Brittany Adams B. Adams **Harnett County Environmental Health**
Environmental Health Specialist Health Department

12/17/19 307 W. Cornelius Harnett Blvd.
Date Address

Forward copies to: Migrant Housing Operator Lillington, NC 27546
Department of Labor
Agriculture Safety & Health Bureau 910-893-7547
Office Phone Number

Evaluation
 Re-evaluation _____
(number)

North Carolina Department of Environment and Natural Resources
Division of Environmental Health
**PREOCCUPANCY EVALUATION REPORT
OF DRINKING WATER SUPPLY AND
WASTEWATER FACILITIES FOR MIGRANT HOUSING**

On 12/17/19, as required in G.S. 95-225(c) and (d), an evaluation was conducted of the drinking water supply and
(date)

wastewater system serving a migrant housing site composed of # of _____ Mobile home units, # of 1 House (s) and

Other type of housing/describe: _____ located at 5845 NC 2105
(address or directions; use reverse if needed)

Bunnlevel and operated by Jimmy Autry
(name of person[s]/company)

of 5845 NC 2105, Bunnlevel NC 28523
(mailing address)

***** PLEASE SUBMIT ONE REPORT FOR EACH SEPTIC SYSTEM *****

This report describes well/spring 0 and sewage system 1. (Use reverse for a drawing, if needed.)
(number) (number)

The findings of this evaluation are as follows:

WATER SUPPLY

Yes Community or non-transient-non-community water system under routine surveillance of Public Water Supply Section,
(yes/no) Division of Environmental Health

NO Private Water or Non-Community System
(yes/no)

At the time of inspection, there was not visual evidence of non-compliance with the "Protection of Water Supplies"
(was/was not)

15A NCAC 18A .1700 (attach copy of bacteriological sample). List deficiencies which were identified:

(Use reverse if necessary)

WASTEWATER FACILITIES

System subject to approval under 15A NCAC 18A .1900, "Laws and Rules for Sewage Treatment and Disposal
(subject/not subject)

Systems." Explain, if not subject to approval _____

On-Site Septic Tank System Chemical Portable Toilets Others _____ Privy(ies) _____

At the time of inspection, there was not visual evidence of non-compliance with 15A NCAC 18A .1900 (including
(was/was not)

.1962) "Laws and Rules for Sewage Treatment and Disposal System." List deficiencies which were identified:

(Use reverse if necessary)

The wastewater system, to the best of my knowledge and belief, is sized to serve 8 people.
(maximum number)

Brittany Adams PETS Beth
Environmental Health Specialist Harnett County Environmental Health
Health Department

12/17/19 307 W. Cornelius Harnett Blvd.
Date Address

Forward copies to: Migrant Housing Operator Lillington, NC 27546
Department of Labor
Agriculture Safety & Health Bureau 910-893-7547
Office Phone Number



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Brittany Adams

Name of System:

HARNETT CO ENVIRONMENTAL HEALTH
 307 CORNELIUS HARNETT BLVD
 Lillington, NC 27546

Jimmy Autry
 164 Deltoro Ln
 Lillington, NC 27546

EIN: 566000306EH

Delivery: NC Courier

Harnett County

StarLiMS ID: **ES191218-0071**

Date Collected: 12/17/2019

Time Collected: 11:00

By: Brittany Adams

Date Received: 12/18/2019

Time Received: 08:13

By: Tyler Best

Sample Source: Well water

Sampling Point: Outside spigot

Sample Type:

GPS No.

Treatment:

Well Permit No.

Comment:

Colilert - Quanti-Tray2000 Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	<1	MPN/100mL	Absent	12/18/2019
E. coli	<1	MPN/100mL	Absent	12/18/2019

Report Date: 12/19/2019

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.

North Carolina Division of Public Health
Occupational and Environmental Epidemiology Branch, Epidemiology Section
BIOLOGICAL ANALYSIS REPORT

Private well water information and recommendations

County: Harnett Name: Jimmy Authy Sample ID Number: _____
Location: 1104 DeHoro Ln, Lillington Reviewer: Brittany Adams

Initial Sample X Confirmation Sample _____

BIOLOGICAL ANALYSIS RESULTS AND RECOMMENDATIONS FOR USES OF YOUR PRIVATE WELL WATER (These recommendations are based on biological analysis only.)

X No coliform bacteria were found in your well water. Your water can be used for all purposes including drinking, cooking, washing dishes, bathing and showering.

_____ Total coliform bacteria were detected in your water sample. Total Coliform are a group of related bacteria that are (with few exceptions) not harmful to humans. A variety of bacteria, parasites, and viruses, known as pathogens, can potentially cause health problems if humans ingest them. EPA considers total coliforms a useful indicator of other pathogens for drinking water. Total coliforms are used to determine the adequacy of water treatment and the integrity of the distribution system

_____ It is recommended that your well water be re-tested to verify that the result is accurate.

_____ Fecal coliform bacteria were detected in the sample. **Do not use the water for drinking, cooking, washing dishes, bathing or showering.**

If the re-test shows contamination by bacteria contact your local health department for assistance. There may be a problem with the construction of the well, the groundwater source, or operation of the well. The well needs to be inspected by the local health department or a local well contractor to determine the problem with the well and to give guidance on how to correct the problem.

Your well water was tested for biological contaminants (total coliform and fecal coliform bacteria). The results were evaluated using the federal drinking water standards.

Drinking water may contain substances that can occur naturally in water or can be introduced into water from man-made sources. Total coliform bacteria are found in soil and fecal coliform bacteria are found in animal and human waste. Total coliform or fecal coliform bacteria in well water indicate that the well may have structural problems or that the well was not properly disinfected.

If you have been drinking the well water and are pregnant, nursing, have a child in the household under 5 years of age, or immunocompromised (such as an individual with AIDS, cancer, hepatitis, dialysis or surgical procedures) inform your physician of these results at your next visit.

If the contamination continues, you should investigate the possibility of drilling a new well or installing a point-of-entry disinfection unit which can use chlorine, ultraviolet light, or ozone.

For further information please contact your county health department or the Occupational and Environmental Epidemiology Branch at 919-707-5900.