
## Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 936 Nursery Rd, Lillington (SR#1117) ISSUED TO: Noelyne Langston NEW | REPAIR X EXPANSION | Site Improvements required prior to Construction Authorization Issuance: Type of Structure: Existing SFD Proposed Wastewater System Type: 25% Reduction Projected Daily Flow: 360 GPD Number of bedrooms: 3 Number of Occupants: 6 Basement Yes No ☐ No Pump Required: Yes May be required based on final location and elevations of facilities Type of Water Supply: Community Public Well Distance from well 50+ feet X Five years Permit valid for: No expiration Permit conditions: Date: 12/23/2019 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules 1950, 1950, 1954, 1954, 1955, 1956, 1957, 1958, and 1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: Noelyne Langston PROPERTY LOCATION: 936 Nursery Rd. Lillington (SR#1117) SUBDIVISION Facility Type: Existing SFD Expansion Basement? Yes × No Basement Fixtures? Yes Type of Wastewater System\*\* 25% Reduction (Initial) Wastewater Flow: 360 (See note below, if applicable ) 25% Reduction Number of trenches 1 Installation Requirements/Conditions Septic Tank Size 1000 gallons Exact length of each trench 300 Trench Spacing: 9 Feet on Center Pump Tank Size \_\_\_\_\_gallons Trenches shall be installed on contour at a Soil Cover: 6 inches Maximum Trench Depth of: 12 \_inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) ft. TDH vs. GPM inches below pipe Aggregate Depth: inches above pipe Conditions: No blades should be in the ground during lot clearing due to limited Soil Depth. WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: 1 understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Date: 12/23/2019 Authorized State Agent: Construction Authorization Expiration Date: 2/7/2020

## Harnett County Department of Public Health Site Sketch

Property Location: 936 NUBCH Rd, Lillmoton (ST	Z# 1117)	)
Issued To: NOCIUM LANGSTON Subdivision		Lot #
Authorized State Agent: BAROL REHS	Date: _	12/20/19



\* Line length will depend on trees cleared. However does not want specific trees deared

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.